




Testing Laboratory 1045.1 accredited by the Czech Accreditation Institute pursuant to  
ČSN EN ISO/IEC 17025:2018

**Strojírenský zkušební ústav, s.p. Zkušební laboratoř**  
**(Engineering Test Institute, Public Enterprise, Testing Laboratory)**  
**Hudcova 424/56b, Medlánky, 621 00 Brno**

Page 1 of 10



## **TEST REPORT**

### **32-10798/2/IP**

**Product:** Intercom

**Type designation:** 2N® IP One

**Order No.:** 9158101

**Customer:** 2N TELEKOMUNIKACE a.s.  
Modřanská 621/72  
143 00 Praha 4  
Czech Republic  
Company ID: 26183960

**Manufacturer:** 2N TELEKOMUNIKACE a.s.  
Modřanská 621/72  
143 00 Praha 4  
Czech Republic

**Employee responsible:** Michal Bauer

**Report issue date:** 2022-06-21

**Distribution list:** 1 copy to the Customer  
1 copy to the Engineering Test Institute

This document may be copied in its entirety without written consent of the Engineering Test Institute. Partial copies are subject to approval. The results of the tests and verifications shall relate only to the products tested as received or presented. The testing laboratory is not responsible for the data provided by the customer specified in the report.

## I. Description of product tested

Intercom, type designation 2N® IP One, order no. 9158101 was submitted for the test of the enclosure.

The product is intended for installation into a wall and for this installation a flush box is used (order number 9158001).

Mass: 355g the unit  
465g unit with flush box  
Dimensions of the unit in (mm): 78 (W) x 172 (H) x 45 (D)  
Dimensions of the flush box in (mm): 123 (W) x 195 (H) x 83.5 (D)

The purpose of the test is to verify the degree of protection provided by enclosures for IP 6X of the sample.

## II. Sample tested

SZU reg. no.	Product name	Date of submission
0231.22.36728.002	Intercom, type designation 2N® IP One, Order No. 9158101	2022-05-17



Fig. 1 Sample in the laboratory premises installed in a wall simulation

The visual inspection, tests and verification were carried out by Michal Bauer at the test station 052 of SZU.

The tests were performed using measuring and testing equipment with valid calibration.



<b>Test objective:</b>	Degrees of protection provided by enclosures IP X6
<b>Exact name of the test procedure:</b>	E 016* - Test of protection degree (except heavy waves)
<b>Test method:</b>	ČSN EN 60529:1993
<b>Sample tested:</b>	0231.22.36728.002
<b>Measuring equipment used:</b>	see Chapter III
<b>Date of test:</b>	2022-05-24

<b>Ambient conditions:</b>	24 °C	51 %	1015 mbar
	Temperature	Relative humidity	Barometric pressure

The second figure indicates that the enclosure:  
 - provides protection against penetration of water

#### Protection against penetration of water IP X6

Test method:	ČSN EN 60529:1993, Art. 14
Test equipment:	See chapter III., items 1 to 8
Jet diameter:	12,5 mm
Distance between the jet and the sample surface:	2,5 m to 3 m
Flow rate:	12,5 l . min <sup>-1</sup> ± 5 %
Test duration:	1 min . m <sup>-2</sup> of the surface, at least 3 min
Test medium:	Water
Temperature of the medium:	22,1 °C
Temperature of the tested sample:	24,3 °C
Position of the sample's enclosure during test:	see fig. 2
Test description:	The sample was exposed to the flow of water, spouting from every direction according to the above mentioned specifications.
Approval conditions:	<p>The protection is satisfactory if the water does not penetrate into the enclosure at all. The water that penetrated into the enclosure shall generally not:</p> <ul style="list-style-type: none"> <li>- be in such quantity to worsen the safety or disrupt the correct function of the equipment</li> <li>- remain on isolating parts to provide possibility of creepage currents</li> <li>- be in contact with live parts or windings that are not intended to work in wet conditions</li> <li>- gather itself near cable endings or penetrate into these endings</li> </ul>
Test results:	<b>After opening the enclosure of the tested sample no water was found inside the sample (see fig. 3 to fig. 10).</b>



Fig. 2 Sample after the test



Fig. 3 Sample after removing part of the back cover



Fig. 4 Back cover of the sample



Fig. 5 Sample after removing the back cover




Fig. 6 Electronic board after the test




Fig. 7 Inner side of the front cover of the sample




Fig. 8 Detail of the front cover after the test  
Water is only in parts not protected by the cover – behind the speaker grating




Fig. 9 Detail of the front cover after the test  
Water is only in parts not protected by the cover – around the button



Fig. 10 Detail of the front cover after the test – the cover of camera

The tests results apply only to the submitted test sample.

Tested by: Michal Bauer  
Reviewed and approved by: Ing. Antonín Heitl

Date: 2022-06-21  
Date: 2022-06-21

Signed: \_\_\_\_\_  
Signed: \_\_\_\_\_

**V. A list of referenced documents**

- Order OPV-0003025 of 2022-05-03 (Order reg. no. B-76333, received on 2022-05-04)
- Contract B-76333/32
- ČSN EN 60529:1993 - Degrees of protection provided by enclosures (IP Code)
- A list of technical documentation:
  - Drawing VILLA PANEL, part number ME 11300033x B, revision B.2 of 2022-05-30
  - Drawing VILLA BACK, part number ME 113000430 B, revision B.2 of 2022-06-13

Test Report compiled by: Michal Bauer



Test Report approved by: Ing. Antonín Heitl  
Head of Electrical Equipment Test Station

– End of Test Report –